

CONFIRMATION

Notification: 0000040334_01_05
on changes according to EN 15267 regarding certificate 0000040334_01 dated 05 November 2019

AMS designation: MEAC300 (DAHS)

Manufacturer: SICK AG
Gisela Sick Straße 1
79276 Reute
Germany

German Federal Environmental Agency (UBA)

**Announcement regarding the uniform practice in
monitoring emissions and ambient air
dated 09 March 2022
Publication: BAnz AT 11.04.2022 B10**

**VI. Notifications as regards the uniform practice in monitoring
emissions and ambient air:**


**46 Notification as regards Federal Environment Agency (UBA) notices
of 28 June 2019 (BAnz AT 22.07.2019 B8, chapter IV number 1.2) and
of 29 June 2021 (BAnz AT 05.08.2021 B5, chapter IV notification 18)**


The current software version for the measuring device MEAC300 (MEAC 2012)
(ID = 0000040334) for emission evaluation system of the company SICK AG is:
4.1.34.30

The versions up to 4.1.34.29 are no longer to be used, as incorrect output may occur in
the reports.

Statement issued by TÜV Rheinland Energy GmbH dated 06 January 2022

TÜV Rheinland Energy GmbH
Cologne, 12 April 2022


i. V. Dipl.-Ing. Guido Baum


i. A. Dipl.-Ing. Carsten Röllig

www.umwelt-tuv.eu
TRE@umwelt-tuv.eu
Tel. +49 221 806-5200

TÜV Rheinland Energy GmbH
Am Grauen Stein
51105 Cologne

Test institute accredited to EN ISO/IEC 17025 by DAkkS (German Accreditation Body).
This accreditation is limited to the accreditation scope defined in the enclosure to the certificate D-PL-11120-02-00.