

CERTIFICATE

of Product Conformity (QAL1)

Certificate No.: 0000054059_01

Evaluation device: D-EMS 2020

Manufacturer: DURAG data systems GmbH
Kollastr. 105
22453 Hamburg
Germany

Test Laboratory: TÜV Rheinland Energy GmbH

This is to certify that the data acquisition and handling system (DAHS)
has been tested and found to comply with the standards:
Uniform practice in monitoring emissions 2017*
and EFÜ interface definition 2017 (remote emission control)
as well as EN 14181 (2014), EN 15267-1 (2009) and DIN EN 15267-2 (2009).

Certification is awarded in respect of the conditions stated in this certificate
(this certificate contains 7 pages).

The present certificate replaces certificate 0000054059 of 13 April 2018.



Suitability Tested
EN 15267
QAL1 Certified
Regular Surveillance


www.tuv.com
ID 0000054059

Publication in the German Federal Gazette
(BAnz) of 22 July 2019

Federal Environment Agency
Dessau, 05 November 2019

Expiry date:
21 July 2024

TÜV Rheinland Energy GmbH
Cologne, 04 November 2019



Dr. Marcel Langner
Head of Section II 4.1



ppa. Dr. Peter Wilbring

www.umwelt-tuv.eu
tre@umwelt-tuv.eu
Phone: + 49 221 806-5200

TÜV Rheinland Energy GmbH
Am Grauen Stein
51105 Köln

Test institute accredited to EN ISO/IEC 17025:2005 by DAkkS (German Accreditation Body).
This accreditation is limited to the accreditation scope defined in the enclosure to the certificate D-PL-11120-02-00.
*Uniform practice in monitoring emissions 2017 - Circular of the FME 23.01.2017- IG I 2 -45053/5

Test Report:	936/21226273/D dated 12 April 2019
Initial certification:	13 April 2018
Expiry date:	21 July 2024
Publication:	BAnz AT 22.07.2019 B8, chapter IV number 1.1

Approved application

The tested DAHS is suitable for emission data acquisition and evaluation of emission measurements at continuously monitored plants. Signals can be transmitted analogously (0–20 mA) and digitally via Profibus and Modbus (EIA-485, serial, Ethernet) in accordance with VDI 4201.

The system also allows for remote emission control via modem and FTPS.

This has been demonstrated by way of a performance test in the laboratory and a three-month field test at a waste incinerator. Additional plant types have been simulated.

The data evaluation system is approved for an ambient temperature range of +5 °C to +40 °C.

Suitability of the DAHS and its performance test were based on the provisions applicable at the time of testing. As changes in legal provisions are possible, any potential user should ensure that this DAHS is suitable for monitoring the measured values relevant to the application.

Any potential user should ensure, in consultation with the manufacturer, that this data evaluation system is suitable for the installation at which it will be installed.

Basis of the certification

This certification is based on:

- Test report no. 936/21226273/D dated 12 April 2019 issued by TÜV Rheinland Energy GmbH
- Suitability announced by the German Federal Environment Agency (UBA) as the relevant body
- The ongoing surveillance of the product and the manufacturing process

Publication in the German Federal Gazette: BAnz AT 22.07.2019 B8, chapter IV number 1.1,
UBA announcement dated 28 June 2019:

Data acquisition and handling system:

D-EMS 2020

Manufacturer:

DURAG data systems GmbH, Hamburg

Field of application:

Emission data acquisition, evaluation and remote control for continuously monitored plants and plants under the Greenhouse Gas Emissions Trading Act (TEHG)

Tested features during performance testing:

- Analogue data transmission
- Digital data transmission in line with VDI standard 4201, parts 1 (general requirements), 2 (Profibus) and 3 (Modbus)
- Remote emission control via modem and FTPS

Software version: 1.1 / 9870

Restriction:

At IP20 and IP21, the DAHS enclosure did not meet the requirement for the degree of protection during the performance test. The DAHS must be installed in an enclosure for evaluation systems which provides a sufficient degree of protection for the intended site of installation. This must be verified in the context of correct installation.

Notes:

1. The DAHS comprises a system for recording analogue and status signals (D-MS 500KE and D-MS 500FC, types 750-453, 750-436, 750-553, 750-536) and a PC running the D-EMS 2020 programme suite.
2. The data evaluation system is also available as compact system with an Atom N2600 processor under the name D-EMS 2020 CS. This system runs the same software, but the number of input channels is limited to 12 analogue and 30 digital inputs.
3. Supplementary test (reflecting TEHG) as regards Federal Environment Agency notices of 21 February 2018 (BAnz AT 26.03.2018 B8, chapter II number 1.1) and of 27 February 2019 (BAnz AT 26.03.2019 B7, chapter IV notification 79).

Test report:

TÜV Rheinland Energy GmbH, Cologne
Report no. 936/21226273/D dated 12 April 2019

Certified product

This certification applies to automated measurement systems conforming to the following description:

The data evaluation system consists of communication and/or top hat rail unit and a PC. The communication (KE) and/or top hat rail (FC) units serve to collect analogue and status signals. A 12bit analogue to digital converter converts analogue to digital signals. The interval for scanning and storing signals is 1/sec.

Data acquisition with the D-MS 500 KE for analogue and status signals

Shielded inputs serve the purpose of data acquisition of current signals between 0–20 mA. For the transformation of the input current into a measured voltage in the input circle a 100 Ω resistance is integrated. An analogue to digital converter each converts shielded measuring circuits into a 12 bit word.

A relay identifies status signals and passes them on as digital signals.

The D-MS 500 communication unit allows data memory over a 32-day period by default, an option for 64, 96 or 128 days (compact flash card) is provided. Each D-MS 500 communication unit allows for a maximum of 11 I/O components.

Overview of technical specifications:

- 3 serial interfaces: 1xRS485, 2xRS232 by default
- 1 RS232 service interface
- 1 Ethernet TCP/IP port
- 1 CAN port (not in use so far)
- 115/230 VAC / 50/60 Hz 100 VA power supply
- Input cards (per card)
- 8 analogue inputs with 12 bit resolution, 0–20 mA, 100 Ω internal resistance
- 15 digital inputs with 24 V internal supply voltage

Data acquisition with the D-MS 500 FC S(P) for analogue and status signals

Signal input

Inputs serve the purpose of data acquisition of current signals between 0–20 mA. For the transformation of the input current into a measured voltage in the input circle a 100 Ω resistance is integrated. An analogue to digital converter each converts measuring circuits into a 12 bit word. Measuring circuits on a module are not galvanically separated.

Status signals are identified via an optocoupler and passed on as digital signals.

Overview of technical specifications:

- Top hat rail mounting
- 24 V DC / max. 550 mA power supply
- 1 serial RS232/RS485 interface
- 1 PROFIBUS DP Slave interface
- 1 service interface (downstream of the cover plate)
- 2 Ethernet TCP/IP ports
- Protocols: Modbus RTU and TCP, Elan-Master, PROFIBUS, OPC UA, Mode4-Master
- Up to 256 analogue inputs 0/4–20 mA/100 Ω (4 per module)
- Up to 256 analogue outputs 0/4–20 mA/0–300 Ω or 300–600 Ω (4 per module)
- Up to 256 analogue inputs (8 per module)
- Up to 256 digital outputs 24 V/0.5 A (8 per module)

Data storage for a period of 32 days (default), optionally for 64 or 96 days on a SD card

Tested analogue input module, Wago type 750-553

Profibus interface

The Profibus Master FNL DP manufactured by COMSOFT GmbH in Karlsruhe is used as the Profibus interface. Revision: 02;SW/FW:2.19.34; HW:02.1, GSD: COMSOA4A.GSD, File Version: September 29, 2011. Data transmission is ensured in accordance with the interface definition provided by VDI guideline 4201, parts 1 (2010) and 2 (2014).

Data evaluation

The software version operated by the D-EMS 2020 data evaluation system is: 1.1 / 9870.

Measured values are evaluated on an industrial computer with the following minimum configuration:

- Intel Core i3, 4 GB RAM, hard drive > 500 GB
- Ethernet interface, RS 232/485 serial optional, USB port, DCF77 receiver, standard printer
- Modem (V92 analogue or ISDN modem) or Internet for remote emission control or maintenance
- Windows 8.1, 10 or Windows Server 2012 R2, 2016 operating system
- For the purpose of back-ups, the PC has to be equipped with a backup drive (e.g. an external hard drive) and/or an Ethernet port for backup on a separate PC

Data evaluation can alternatively be performed on a **D-EMS 2020 CS compact computer** which features the following minimum specifications:

- Operating system: Windows 8.1 and 10
- Processor: Intel Atom N2600 or higher
- Hard drives: min. 300 GB
- Main memory: 2048 MB RAM
- Ethernet interface
- 3 serial (RS 232) optional / USB ports
- DCF77 receiver
- Modem (external standard V92 analogue modem) for remote emission control or maintenance, optional
- External hard drive, optional
- Up to 12 analogue outputs 0/4–20 mA / 100 Ω (8 each per D-MS 500 No51/50 board) (= > max. 16 components: 12 analogue outputs + 4 computing channels)
- Up to 24 digital relay inputs (15 each per D-MS 500 No51/50 board)
- Up to 24 digital relay outputs 24V/5VA (16 each per D-MS 285 No13 board)
- Up to 12 analogue outputs 0/4–20 mA/500 Ω (8 D-MS 500 No16 board)

The evaluation system was against the following requirements:

- Uniform practice in monitoring emissions (BEP):
Circular of the Federal Ministry of Environment dated 23 January 2017 - IG I 2 -45053/5
- Remote emission control (EFÜ)/interface definition
version amended by LAI decision of 28 September 2005, latest version of April 2017
- EN 14181:2014-11 (Stationary source emissions, quality assurance of automated measuring systems): Standard applies to the evaluation of data obtained from emission monitoring systems
- VDI guideline 4201
Performance criteria on automated measuring and electronic data evaluation systems for monitoring emissions – Digital interface –
Part 1 – General requirements (2010)
Part 2 – Specific requirements for Profibus (2014)
Part 3 – Specific requirements for Modbus (serial and TCP/IP) (2012)

General remarks

This certificate is based upon the equipment tested. The manufacturer is responsible for ensuring that on-going production complies with the requirements of the EN 15267. The manufacturer is required to maintain an approved quality management system controlling the manufacturing process for the certified product. Both the product and the quality management system shall be subject to regular surveillance.

If a product of the current production does not conform to the certified product, TÜV Rheinland Energy GmbH must be notified at the address given on page 1.

A certification mark with an ID-Number that is specific to the certified product is presented on page 1 of this certificate.

This document as well as the certification mark remains property of TÜV Rheinland Energy GmbH. Upon revocation of the publication the certificate loses its validity. After the expiration of the certificate and on request of TÜV Rheinland Energy GmbH this document shall be returned and the certificate mark must no longer be used.

The relevant version of this certificate and its expiration date are also accessible on the internet at qal1.de.

Document history

Certification of the D-EMS 2020 data acquisition and handling system is based on the documents listed below and the regular, continuous surveillance of the manufacturer's quality management system:

Initial certification according to EN 15267

Certificate no. 0000054059_00: 13 April 2018
Expiry date of the certificate: 25 March 2023
Test report 936/21226273/B dated 30 September 2017
TÜV Rheinland Energy GmbH, Cologne
Publication: BAnz AT 26.03.2018 B8, chapter II number 1.1
UBA announcement dated 21 February 2018

Notification in accordance with EN 15267

Statement issued by TÜV Rheinland Energy GmbH dated 23 January 2019
Publication: BAnz AT 26.03.2019 B7, chapter IV notification 79
UBA announcement dated 27 February 2019
(Software update to include a moving monthly average)

Supplementary testing according to EN 15267

Certificate no. 0000054059_01: 05 November 2019
Expiry date of the certificate: 21 July 2024
936/21226273/D dated 12 April 2019
TÜV Rheinland Energy GmbH, Cologne
Publication: BAnz AT 22.07.2019 B8, chapter IV number 1.1
UBA announcement dated 28 June 2019